



Grants/denies access to device connected to 'Access' connection output for a specified amount of time.


TYPE FEATURES

Control: Relay Input	Access: Relay Output	Message Time	Verify Time	Verification	Show Length	Lockout
Required	Required	Required	Required	Required	Required	Optional

EXPERIENCE

Normal RI 10 N 56 al € 4 ☐ 〈 Code Agent Cindev **⊕**





Verified

Notes

- Make sure to allow for enough time to close the application and find the accompanying button that is unlocked by the Code Agent
- We suggest favoriting the Code Agent and the accompanying button in the same room right next to each other as shown in the example above
- If both Access and Control relay connections are not made when using the code type, the driver will enter an OFFLINE state

 Though the driver can be bound to any relay binding there may be limitations

 Ex.: The lock proxy does not pass proxy commands correctly through the relay connection.
- There are workarounds but they are not recommended as they do not survive a reboot.